



EN 858-1



I'd like to order

I'd like a quote

Mark the installation depth of the tank h (depth from the ground to the bottom of the inlet pipe in mm).

h =

Notes (name of project or address, special need etc):

No	NAME	MATERIAL	SIZE	Qn/pcs
1	Separators body	PE-HD	D1300,H1320	1
2	Inlet-outlet pipe	PE-HD	D160 mm	1
3	Inspection well (choose right depth)	PE-HD	D600 mm	1
Installation depth h is measured from inlet pipe bottom to groundlevel in mm. On special occasions we can adapt the body for deeper installation)				
4	Ventilationpipe	PE	D110 mm	1
5	Oil coalescence unit EC-filter			1
V	Total volume		1600 dm3	
V _o	Oillayer volume		200 dm3	
V _m	Sand-mud volume		1000 dm3	
ADDITIONAL EQUIPEMENT				
.	Telescopic cover D600 mm (make Your choice)			
7	Oillayer alarm (make Your choice)			
8	Automatic closing valve (make Your choice)			

Please send the completed form by e-mail

Please check your selections and measurements before sending

Date	Engin	Signature	Sheets	OILSEPARATOR I class EC Name.	NS10
eccua		Mass	Number	RV	